

DECLARATION OF PERFORMANCE

No. UKCAIL0001-02

1. Unique identification code of product-type:
ILISP
2. Type, batch or serial number or any other element allowing identification of the construction product as required under article 11(4):
Shower enclosure
3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:
Personal hygiene (PH)
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):
Flair Showers Ltd., Rocks Road, Kingscourt, Co. Cavan, Ireland
T 00353 42 966 8000
F 00353 42 969 3672
E sales@flairshowers.com
5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):
No authorised representative
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:
System 4
7. In case of the declaration of performance concerning a construction product covered by a harmonised standard.
Determination of the product type and factory production control by the manufacturer
8. Declared performance

Essential Characteristics ^a	Performance	Harmonized technical specification
Cleanability	Pass	EN 14428:2015+A1:2018
Impact resistance/shatter properties	Pass	
Durability	Pass	
^a Specific performance of essential requirements are given by the designation code as cited in the attachment.		

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.
This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Sign for and on behalf of the manufacturer by:




Ronán O'Grady, Product Designer Conex Works, Santry Avenue, Santry, Dublin 9, Ireland 18.11.2020

Attachment to Declaration of Performance

No. UKCAILI0001-02

Product code no.	Description	CE Marking
ILISP70SC	ILI SIDE PANEL 700mm Silver	CA-IR-DA
ILISP70BRBC	ILI SIDE PANEL 700mm Brushed Brass	CA-IR-DA
ILISP76SC	ILI SIDE PANEL 760mm Silver	CA-IR-DA
ILISP80SC	ILI SIDE PANEL 800mm Silver	CA-IR-DA
ILISP80BRBC	ILI SIDE PANEL 800mm Brushed Brass	CA-IR-DA
ILISP90SC	ILI SIDE PANEL 900mm Silver	CA-IR-DA
ILISP90BRBC	ILI SIDE PANEL 900mm Brushed Brass	CA-IR-DA
ILISP100SC	ILI SIDE PANEL 1000mm Silver	CA-IR-DA
ILI180SP100SC	ILI SIDE PANEL 1000mm Silver 1800mm High	CA-IR-DA
ILI180SP70SC	ILI SIDE PANEL 700mm Silver 1800mm High	CA-IR-DA
ILI180SP80SC	ILI SIDE PANEL 800mm Silver 1800mm High	CA-IR-DA
ILI180SP90SC	ILI SIDE PANEL 900mm Silver 1800mm High	CA-IR-DA
ILIFSP70SC	ILI Frameless Side Panel 700mm Silver	CA-IR-DA
ILIFSP76SC	ILI Frameless Side Panel 760mm Silver	CA-IR-DA
ILIFSP80SC	ILI Frameless Side Panel 800mm Silver	CA-IR-DA
ILIFSP90SC	ILI Frameless Side Panel 900mm Silver	CA-IR-DA
ILIFSP100SC	ILI Frameless Side Panel 1000mm Silver	CA-IR-DA

Sign for and on behalf of the manufacturer by:



Ronán O' Grady, Product Designer Conex Works, Santry Avenue, Santry, Dublin 9, Ireland 18.11.2020


Flair Showers Ltd., Rocks Road, Kingscourt, Co. Cavan, Ireland 20 UKCAIL0001-02
ILISP PH EN 14428 CA-IR-DA

Characteristic to be tested	Assessment method according to clauses of document I.S. EN 14428:2015+A1:2018	Number of samples	Compliance criteria
Cleanability	4.2	1	4.2
Impact resistance/shatter properties	5.1, 5.2	1	4.3
Corrosion resistance	4.4.2	1	4.4.2
Resistance to chemicals and stains	5.3	1	4.4.3
Resistance to wet and dry cycling	5.4	1	4.4.4
Endurance	5.5	1	4.4.5
Stability	5.6	1	4.4.6
Water retention	5.7	1	4.4.7

This is to certify that the following product has achieved a pass under each and all of the EN requirements for shower enclosures, as covered by the scope of EN14428:2015+A1:2018.

ILISP – ILI Side Panel – Certificate Number UKCAIL0001-02



Ronán O'Grady, Product Designer Conex Works, Santry Avenue, Santry, Dublin 9, Ireland 18.11.2020